

# Factsheet

## Lit candles and related products

Please note that lit candles are not permitted in the exhibition halls as a general rule. Lit candles may be approved subject to certain requirements in agreement with the Fire Prevention Department of the Frankfurt Fire Brigade (as exhibits and/or with candle holders being exhibited).

These requirements are as follows:

1. For safety reasons, candles may only be used when placed behind glass (lanterns) or in containers filled with water (floating candles).
2. Lit candles are forbidden outside of the stand.
3. Candles must also be positioned carefully within the stand, to ensure that visitors do not inadvertently create a dangerous situation. A minimum distance of 0.50 m from flammable materials must be maintained.
4. For fire safety reasons, lit candles are not permitted in shelving.
5. A quantity appropriate for product presentation (2-3 candles) may not be exceeded.
6. The exhibitor / stand operator bears sole responsibility for any consequential damage. Messe Frankfurt Venue GmbH is not liable for any damage.

Messe Frankfurt Venue GmbH  
Technical Event Management